





TEST REPORT EN 54-4 Part 4: Power supply equipment	
Report Number : 6131759.50 Date of issue : 2022-09-16 Total number of pages : 62	
Name of Testing Laboratory preparing the Report :	DEKRA Testing and Certification (Shanghai) Ltd.
Applicant's name :	MEAN WELL Enterprises Co., Ltd.
Address :	No.28, Wuquan 3rd Rd., Wugu District, 24891 New Taipei City, Taiwan
Test specification:	
Standard :	EN 54-4:1997+A1:2002+A2:2006
Test procedure :	Type test
Non-standard test method :	N/A
Test Report Form No. :	EN54-4_a
Test Report Form(s) Originator :	DEKRA
Master TRF :	Dated 2022-08
General disclaimer: The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of DEKRA. The authenticity of this Test Report and its contents can be verified by contacting the DEKRA, responsible for this Test Report.	

Test item description	Power supply equipment	
Trade Mark(s)		
Manufacturer	Same as applicant	
Model/Type reference	DRS-240-12, DRS-240-24, DRS-240-36, DRS-240-48	
Ratings	<p>DRS-240-12: Input: 100-277 Vac, 50 / 60 Hz, 2,8 A Output: 12 Vdc, Max. 20 A BAT: 12 Vdc, Max. 15,4 A</p> <p>DRS-240-24: Input: 100-277 Vac, 50 / 60 Hz, 2,8 A Output: 24 Vdc, Max. 10 A BAT: 24 Vdc, Max. 7,7 A</p> <p>DRS-240-36: Input: 100-277 Vac, 50 / 60 Hz, 2,8 A Output: 36 Vdc, 6,67 A BAT: 36 Vdc, 5,1 A</p> <p>DRS-240-48: Input: 100-277 Vac, 50 / 60 Hz, 2,8 A Output: 48 Vdc, 5 A BAT: 48 Vdc, 3,85 A</p>	
Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
Testing Laboratory:	DEKRA Testing and Certification (Shanghai) Ltd.	
Testing location/ address	3F #250, Jiangchangsan Road Building 16, Headquarter Economy Park Shibe Hi-Tech Park, Jing'an District, Shanghai 200436, China	
Tested by (name, function, signature)	Louis Kang	
Approved by (name, function, signature)	Keith Wei	