




Ref. Certif. No.

DK-130443-M2-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switching Power Supply
Name and address of the applicant	MEAN WELL ENTERPRISES CO LTD No.28, Wuquan 3rd Rd., Wugu District., New Taipei City 24891 Taiwan
Name and address of the manufacturer	MEAN WELL ENTERPRISES CO LTD No.28, Wuquan 3rd Rd., Wugu District., New Taipei City 24891 Taiwan
Name and address of the factory	MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891, Taiwan
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Model RST-7K5-115: 220-277VAC, 3W+PE, 23A, Δ 220-277VAC/380-480VAC, 3W+PE+N, 13A, Y 50/60Hz See original test report for details
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	RST-7K5-xy and RST-15K-x (x = 115, 230 or 380 and y = L or blank)
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to: EN 62368-1:2014, EN 62368-1:2014/A11:2017 The report was revised to include technical modifications. National Differences: EU Group Differences, AU, CA, DK, IT, JP, NZ, SA, GB, US <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	2312094-1-CB-M2 issued on 2024-01-16

This CB Test Certificate is issued by the National Certification Body



- UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2024-01-17
Original Issue Date: 2022-07-29

Signature: Thomas Wilson



Ref. Certif. No.

DK-130443-M2-UL

Factory(ies):

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD
No.11 Jingu South Road, Huadu District, Guangzhou Guangdong 510890,
China

SuZhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town, Xiang-cheng District, Suzhou, Jiangsu 215152,
China.

YONGDEN TECHNOLOGY CORP
345 MacArthur Hwy, Tabang, Guiguinto, Bulacan 3015,
Philippines

SuZhou MEAN WELL Technology Co., Ltd.
No.269, Changping Rd, Huangdai Town Xiangcheng District, Suzhou, Jiangsu, 215152,
China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058,
India

Summary of Modifications:

Correction of TEST ITEM PARTICULARS;

Addition tests with specific conditions for Model RST-7K5-380L, tests for reference only per manufacturer's request.

Additional information (if necessary)



- UL Solutions (US), 333 Pflugsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2024-01-17

Original Issue Date: 2022-07-29

Signature:

Thomas Wilson



Ref. Certif. No.

DK-130443-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product: Switching Power Supply
Name and address of the applicant: MEAN WELL ENTERPRISES CO LTD, NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 Taiwan

Name and address of the manufacturer: MEAN WELL ENTERPRISES CO LTD, NO 28 WUQUAN 3RD RD WUGU DISTRICT NEW TAIPEI CITY 24891 Taiwan

Name and address of the factory: MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891, Taiwan

Note: When more than one factory, please report on page 2

Ratings and principal characteristics: Model RST-7K5-115: 220-277VAC, 3W+PE, 23A, Δ 220-277VAC/380-480VAC, 3W+PE+N, 13A, Y 50/60Hz See test report for details

Trademark / Brand (if any): MW MEAN WELL logo

Customer's Testing Facility (CTF) Stage used: CTF Stage 2

Model / Type Ref.: RST-7K5-xy, RST-15K-x (x = 115, 230 or 380 and y = L or blank)

Additional information (if necessary may also be reported on page 2): Additionally evaluated to: EN 62368-1:2014, EN 62368-1:2014/A11:2017 The report was revised to include technical modifications. National Differences: EU Group Differences, AU, CA, DK, IT, JP, NZ, SA, GB, US

A sample of the product was tested and found to be in conformity with: IEC 62368-1:2014

As shown in the Test Report Ref. No. which forms part of this Certificate: E183223- 4790983741-CB-1, amendment 1 issued on 2023-12-25

This CB Test Certificate is issued by the National Certification Body



- UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-12-28
Original Issue Date: 2022-07-29

Signature: Thomas Wilson



Ref. Certif. No.

DK-130443-M1-UL

Factory(ies):

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD
No.11 Jingu South Road, Huadu District, Guangzhou Guangdong 510890,
China

SuZhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town, Xiang-cheng District, Suzhou, Jiangsu 215152,
China

YONGDEN TECHNOLOGY CORP
345 MacArthur Hwy, Tabang, Guiguinto, Bulacan 3015,
Philippines

SuZhou MEAN WELL Technology Co., Ltd.
No.269, Changping Rd, Huangdai Town Xiangcheng District, Suzhou, Jiangsu, 215152,
China

MEAN WELL INDIA ELECTRONICS PRIVATE LIMITED
9C, Peenya industrial area, Chokkasandra, 2ND PHASE, PEENYA, Bengaluru (Bangalore) Urban, Karnataka, 560058,
India

Summary of Modifications:

Added a new construction B;
Added two factories;
See test report for details.

Additional information (if necessary)



- UL Solutions (US), 333 Pflingsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-12-28
Original Issue Date: 2022-07-29

Signature:

Thomas Wilson




Ref. Certif. No.

DK-130443-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switching Power Supply
Name and address of the applicant	MEAN WELL ENTERPRISES CO LTD No.28, Wuquan 3rd Rd., Wugu District., New Taipei City 24891 Taiwan
Name and address of the manufacturer	MEAN WELL ENTERPRISES CO LTD No.28, Wuquan 3rd Rd., Wugu District., New Taipei City 24891 Taiwan
Name and address of the factory	MEAN WELL Enterprises Co., Ltd. No.28, Wuquan 3rd Rd., Wugu District, New Taipei City 24891, Taiwan
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	Model RST-7K5-115: 220-277VAC, 3W+PE, 23A, Δ 220-277VAC/380-480VAC, 3W+PE+N, 13A, Y 50/60Hz See test report for details
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	RST-7K5-xy, RST-15K-x <input checked="" type="checkbox"/> Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to: EN 62368-1:2014, EN 62368-1:2014/A11:2017 National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	2204033-1-CB issued on 2022-07-22

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-07-29

Signature:
Jan-Erik Storgaard



Ref. Certif. No.

DK-130443-UL

Factory(ies):

MEAN WELL (GUANGZHOU) ELECTRONICS CO., LTD
No.11 Jingu South Road, Huadu District, Guangzhou Guangdong 510890, China

SuZhou MEAN WELL Technology Co., Ltd.
No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town, Xiang-cheng District, Suzhou, Jiangsu 215152, China

YONGDEN TECHNOLOGY CORP
345 MacArthur Hwy, Tabang, Guiguinto, Bulacan 3015, Philippines

Additional Model Detail(s):

RST-7K5-xy, RST-15K-x, (x = 115, 230 or 380 and y = L or blank)

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-07-29

Signature:

Jan-Erik Storgaard